



ADDENDUM NO. 1
UPS POWER PROTECTION
TU-1018

October 30, 2009

Ladies and Gentlemen:

Procurement

Towson University
8000 York Road
Towson, MD 21252-0001

t. 410 704-2171
f. 410 704-8233

The purpose of this addendum is to clarify certain portions of the above-referenced project with all prospective Bidders.

CLARIFICATIONS:

Auto restart is required on all units.

Training to be provided on site.

Two year Powerware warranty is an onsite warranty.

QUESTIONS:

Q1. The University's residential data equipment list has a column label, # of Cisco Devices. Do the numbers in this column represent the number of Cisco switches? Please define what the numbers in that column mean in regards to the number Cisco switch power supplies. Specifically, can you identify the quantity of power supplies that will need to plug into a UPS in rooms 1137 and 2137?

A1. The column entitled # of Cisco devices is the number of physical Cisco switches within that hub room. The next column tells the Power Supply wattage. Next column indicates the number of power supplies per switch with the next column indicating the number of plugs per power supply. For room 1137 and 2137, there is one Cisco 6509 switch with two 6000W power supplies with two power plugs per each power supply. The vendor shall determine the appropriate design to supply a solution which includes all other requirements within the bid document.

Q2. How many available wall receptacles are there in each room that can be used to plug in the UPS's?

A2. The installed UPS units need to be plugged into the receptacles that are currently being used by the Cisco switches. There are no additional receptacles in each hub room for this project.

Q3. What is the wattage for the Cisco 3750 switch?

A3. 541 watts

Q4. What is the current number of units on the existing software and what is the remaining available capacity?

A4. Our current management software resides on two servers and had capacity for 200 UPS units per server. At this time, we have plenty of capacity for new UPS units to be added by the vendor.

All addenda will be incorporated into the final contract documents and will be binding on all vendors responding to this solicitation. Each vendor submitting a bid/proposal must acknowledge receipt of all addenda by completing and forwarding Exhibit K (included in the bid package) with the bid response; failure to acknowledge addenda may result in bid/proposal rejection.

If you have any questions regarding this addendum, please contact me at (410) 704-2048 or email me at cwettersten@towson.edu.

Sincerely,



Carol Wettersten
Procurement Officer Representative

CW:ar